

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

August 20, 2013

CLAYTON HOMES - CREST HOMES CMH MFG. WEST INC. - PLANT 981 BRYAN PROVIDAKES 437 N MAIN ST PO BOX 1218 MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: CLAYTON HOMES - CREST HOMES

Product Name: MID-5707 Model Number(s): MID-5707 Product File No: 20130254

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2018.

This approval is contingent upon compliance with the following stipulation(s):

- 1. SPS 382.20(12)—AAV's installed per stipulations.
- 2. The flowing water supply pressure at the point(s) of connection must be at least 34.64 psig.
- 3. The manufacture must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- 4. This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-267-9723 Fax
tim.lamb@wi.gov E-mail

SBD-10564-E (N.10/97)

File Ref: 20130254_approval letter.DOC